

## E-Coder Code Number Definitions

	<b>NoFlowDays</b> (Consecutive Days of No Flow detected in the last 35 days)	<b>PeakBackFlow</b> (Continuous BackFlow detected in the last 35 days)	<b>Leak35Days</b> (Total Number of Days a leak was detected in the last 35)	<b>LeakCurrent</b> (Leak detection in last 24 hours)
<b>Code = 0</b>	0 (Flow every day)	0 to Minimum Value	0 (No leak detected)	No leak detected
<b>Code = 1</b>	1-2	Minimum to Maximum Value	1-2	Intermittent leak
<b>Code = 2</b>	3-7	Greater Than Maximum Value	3-7	Continuous leak
<b>Code = 3</b>	8-14	N/A	8-14	N/A
<b>Code = 4</b>	15-21	N/A	15-21	N/A
<b>Code = 5</b>	22-34	N/A	22-34	N/A
<b>Code = 6</b>	35 (No Flow detected in last 35 days)	N/A	35 (Leak detected every day for the last 35 days)	N/A