

SUBMITTAL INFORMATION





ADAPTER RINGS TO BUSH METER SPUDS (NO CHANGE IN METER LENGTH)



DESCRIPTION		LENGTH	APPROX.	PART	✓ SUBMITTED
SMALL SPUD SIZE	LARGE SPUD SIZE		Wt. LBS.	Number	ITEM(S)
5/8"	5/8"x3/4"	3/8"	0.2	A12S	
5/8"	5/8"x3/4"	9/16"	0.2	A12M	
5/8"	5/8"x3/4"	11/16"	0.3	A12L	
3/4"	1"	9/16"	0.5	A34S	
1"	1-1/4"	5/8"	0.4	A45	

FEATURES

- All brass conforms to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS NO C83600 - 85-5-5-5)
- Meter Adapter Rings are furnished in pairs
- Conforms to AWWA C700 for meter threads

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.

03/03/16



The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443 Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167

www.fordmeterbox.com

Submitted By:

