

SUBMITTAL INFORMATION





ADAPTER TO CHANGE METER SPUD SIZE AND LENGTH



FEATURES

1-7/8"

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (UNS C89833)
- The product has the letters "NL" cast into the body for proper indentification
- Brass components that do not come in contact with potable water confrom to AWWA Standard C800 (ASTM B-62 and ASTM B584, UNS C893600-85-5-5-5)
- Approved to ANSI/NSF Standard 61 2007a

1-1/2"

- 1-1/2" flange is tapped for two 1/2" x 1-1/4" zinc plated bolts, which are included
- Two 5/8" x 2" zinc-plated bolts and nuts are included for the 2" flange

2"

Flange Meter Adapters are sold and furnished in pairs

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443 Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167 http://www.fordmeterbox.com

02/28/13

Submitted By:

A67-NL

9.0

